

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017195	Deltabar S FMD78 FMD78-AAA7F11MT2BU	1	ST

010	Approval:	A	Non-hazardous area
020	Output; Operating:	A	4-20mA HART; extern + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland T14 = side cover (Ex d > M20 thread)
040	Nominal Range; Cell Material; PN:	7F	500mbar/50kPa/7.5psi; 316L; 160bar/ 16MPa/2400psi
050	Calibration; Unit:	1	Nominal range; mbar/bar
060	Membrane Material:	1	316L
080	Process Connection:	MT	DIN11851 DN80 PN25 slotted-nut, 316L, EHEDG, 3A
090	Fill Fluid:	2 m capillary, vegetable oil
100	Additional Option 1:	B	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate
110	Additional Option 2:	U	Mounting bracket, wall/pipe, 316L, heavy duty design