

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943490-9000	Liquiphant M FTL50 FTL50-HBG2AA6G7C	1	ST

010	Approval:	H	ATEX II/IECEX 1G Ex ia IIC T6 Ga
020	Process Connection:	BG2	DN50 PN25/40 A, 316L flange EN1092-1 (DIN2527 B)
030	Probe Length; Type:	AA	Compact; Ra<3.2um/126uin
040	Electronics; Output:	6	FEL56; SIL NAMUR (L-H signal)
050	Housing; Cable Entry:	G7	T13 IP66/68 Alu, coated; M20 gland, separate conn. compartment (EEx d > M20 thread)
060	Additional Option:	C	EN10204-3.1 material (wetted parts) inspection certificate