

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943491-9000	Liquiphant M FTL51 FTL51-FGR2BB8G6A	1	ST

010	Approval:	F	ATEX II 1/2GD Ex ia IIC T6, WHG/IECEEx zone 0/1
020	Process Connection:	GR2	Thread ISO228 G1, 316L
030	Probe Length; Type:	BB	387 mm mm; 316L, Ra<3.2um/126uin
040	Electronics; Output:	8	FEL58;SIL NAMUR+test button (H-L signal)
050	Housing; Cable Entry:	G6	F15 IP66/67 316L hygiene; M20 gland
060	Additional Option:	A	Basic version